

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130122-R26168  
**Report Reference** R26168-2010-07-08  
**Issue Date** 2013-January-22  
**Issued to:** LENCO BITAR S A R L  
M Kalles St 8  
PO Box 55055  
Sin El Fil  
Beirut, Lebanon

**This is to certify that**  
**representative samples of** Fire Door Louvers

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** ANSI/UL 10B, "Fire Tests of Door Assemblies." – Edition 10 – Revision Date 2009/04/13

ANSI/UL 10C, "Positive Pressure Fire Tests of Door Assemblies." – Second Edition - Issued Date 2009/01/26

CAN/ULC-S104, "Standard Method for Fire Tests of Door Assemblies." – Third Edition – Issued Date 2010/07/01

**Additional Information:** See the UL Online Certifications Directory at [www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

Model VENTOR.

Louvers may be provided for Classified hollow-metal type and composite type fire doors.

Louver size not exceeding 610 mm (24 in.) in width and 610 mm (24 in) in height.

William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

